



1. EXTENSION STEM LENGTH = E - G - 1"
2. STEM GUIDE RECOMMENDED FOR STEM LENGTHS GREATER THAN 20 ft.
3. A - TO BE SPECIFIED BY CONTRACTOR FOR PROPER SIZING OF "FLOOR BOX" (8", 10" or 12")

Revised 4-29-98

FLOOR BOX INSTALLATION - DIRECT NUT VALVE

DATE 10-1-87

VAL-MATIC® VALVE AND MANUFACTURING CORP.

DRWG. NO.

SS-596