



WORKING PRESSURE
150 P.S.I. COLD WORKING PRESSURE-C.W.P.

TEST PRESSURE
1.5 TIMES COLD WORKING PRESSURE-C.W.P.

- | | |
|----------------|-------------------|
| 1 BODY | 7 BOLTS |
| 2 COVER | 8 RETAINING SCREW |
| 3 BAFFLE | 9 GUIDE BUSHING |
| 4 SEAT | 14 PIPE PLUG |
| 5 FLOAT | 20 GUIDE SHAFT |
| 5L LOWER FLOAT | 28 PIPE PLUG |
| 6 GASKET | 36 PIPE PLUG |

SEE DRAWING NO. VM-301A-M FOR STANDARD MATERIALS OF CONSTRUCTION.
SEE DRAWING NO. VM-301ASV-M FOR SUPER VALVE MATERIALS OF CONSTRUCTION.

Revised 2-3-10

WASTEWATER AIR/VACUUM VALVE

DATE 3-16-00

VAL-MATIC® VALVE AND MANUFACTURING CORP.

DRWG. NO.
VM-301A