



WORKING PRESSURE
150 P.S.I. COLD WORKING PRESSURE-C.W.P.

TEST PRESSURE
1.5 TIMES COLD WORKING PRESSURE-C.W.P.

125 LB. CLASS
FLANGE

	MODEL NO.		
	304	306	308
A	11.50"	14.00"	17.25"
B	36.50"	36.50"	40.13"
INLET	4" FLG.	6" FLG.	8" FLG.
OUTLET	4" NPT	6" NPT	8" NPT

- | | | | |
|----|-------------|----|-----------------|
| 1 | BODY | 8 | RETAINING SCREW |
| 2 | COVER | 9 | GUIDE BUSHING |
| 4 | SEAT | 15 | CUSHION |
| 5 | FLOAT | 20 | GUIDE SHAFT |
| 5L | LOWER FLOAT | 27 | WASHER |
| 6 | GASKET | 28 | PIPE PLUG |
| 7 | COVER BOLT | | |

SEE DRAWING NO. VM-304-M FOR STANDARD MATERIALS OF CONSTRUCTION.

Revised 6-1-07

WASTEWATER AIR/VACUUM VALVE

DATE 6-5-78

VAL-MATIC[®]

VALVE AND MANUFACTURING CORP.

DRWG. NO.

VM-304