

SWING-FLEX[®] CHECK VALVE

SERIES NO.500AMI & 500MI

STANDARD MATERIALS OF CONSTRUCTION

<u>PART NO.</u>	<u>PART NAME</u>	<u>MATERIAL</u>
1	BODY BODY	DUCTILE IRON ASTM A536, GRADE 65-45-12 (SERIES 500A) CAST IRON ASTM A126, CLASS B (SERIES 500)
2	COVER COVER	DUCTILE IRON ASTM A536, GRADE 65-45-12 CAST IRON ASTM A126, CLASS B
3	DISC	BUNA-N W/ ALLOY STEEL & NYLON REINFORCEMENT
4	COVER SEAL (4"-48") COVER SEAL (2"-3")	BUNA-N COMPRESSED NON-ASBESTOS FIBER
5A	COVER BOLT	ALLOY STEEL SAE GRADE 5, PLATED
5B	COVER BOLT NUT (4"-12")	ALLOY STEEL, PLATED
5C	WASHER	ALLOY STEEL, PLATED
14	MECHANICAL INDICATOR (OPTIONAL, SIZES 3"-48")	ALUMINUM BRONZE, 17-4 STAINLESS STEEL

NOTE: ALL SPECIFICATIONS AS
LAST REVISED.

Revised 5-18-11

MATERIALS OF CONSTRUCTION

DATE 8/13/08

VAL-MATIC[®]

VALVE AND MANUFACTURING CORP.

DRWG. NO.

VM-503AMI-M