

**ECENTRIC PLUG VALVE**  
**Val-Matic® Specification**

**1 Scope**

**1.1** This specification covers the design, manufacture, and testing of 1/2 in. (15 mm) through 3 in. (80 mm) Threaded Eccentric Plug Valve, 2 1/2 in. (60 mm) through 60 in. (1500 mm) Eccentric Plug Valve, and 4 in. (100 mm) through 60 in. (1500 mm) 100% Port Eccentric Plug Valve suitable for water or wastewater service with pressures up to 250 psig (1725 kPa).

**1.2** Plug Valves shall be quarter-turn, non-lubricated with resilient encapsulated plug.

**2 Standards, Approvals and Verification**

**2.1** 2 1/2 in. (60 mm) through 60 in. (1500 mm) plug valves shall be designed, manufactured and tested in accordance with American Water Works Association Standard ANSI/AWWA C517.

**2.2** All Plug Valves shall be certified Lead-Free in accordance with NSF/ANSI 372.

**2.3** Manufacturer shall have a quality management system that is certified to ISO 9001 by an accredited, certifying body.

**3 Connections**

**3.1** Threaded valves shall have threaded NPT full size inlets. The connection shall be hexagonal for a wrench connection.

**3.2** Flanged valves shall have flanges with drilling to ANSIB16.1, Class 125.

**3.3** Mechanical Joint valves shall fully comply with ANSI/AWWA C111/A21.11.

**4 Design**

**4.1** Threaded and all other valves under 4" (100mm) shall have port areas of not less than 100% of pipe area. Port areas on other sizes are 85% on 16" (400 mm) and smaller, 80% on 18"-24" (150 mm- 600 mm), and 75% on 30" (800 mm) and larger.

**4.2** Threaded valve seat shall be a machined seating surface.

**4.3** 2 1/2 in. (60 mm) through 60 in. (1500 mm) plug valves shall have a valve seat that is a welded overlay of 95% pure nickel applied directly to the body on a pre-machined, cast seating surface and machined to a smooth finish.

**4.4** Threaded valves shall have shaft seals which consist of V-type lip seal in a fixed gland with a resilient O-ring spring.

**4.5** 2 1/2 in. (60 mm) through 60 in. (1500 mm) plug valves shall have shaft seals which consist of V-type packing in a fixed gland with an adjustable follower designed to prevent over compression of the packing and to meet design parameter of the packing manufacturer. Removable POP™ shims shall be provided under the follower flanges to provide for adjustment and prevent over tightening.

**4.6** Permanently lubricated, radial shaft bearings shall be supplied in the upper and lower bearing journals. Thrust bearings shall be provided in the upper and lower journal areas, except for threaded type which only have upper thrust bearings.

**4.7** Both the packing and bearings in the upper and lower journals shall be protected by a Grit-Guard™ "drip tight" Buna-N shaft seal located on the valve shaft to minimize the entrance of grit into the bearing journal and shaft seal areas.

**4.8** The threaded valve body shall have 1/8" NPT upstream and downstream pressure ports.

**5 Materials**

**5.1** Valve bodies and covers shall be constructed of ASTM A126 Class B cast iron for working pressures up to 175 psig (1200 kPa) and ASTM A536 Grade 65-45-12 for working pressures up to 250 psig (1725 kPa). The words "SEAT END" shall be cast on the exterior of the body seat end.

**5.2** Threaded valve plugs in sizes 1/2 in. (15 mm) through 3 in. (80 mm) shall be of one-piece construction and made of ASTM A126 Class B cast iron fully encapsulated with a resilient facing per ASTM D2000-BG and ANSI/AWWA C517 requirements.

**5.3** 2 1/2 in. (60 mm) through 60 in. (1500 mm) plugs shall be of one-piece construction and made of ASTM A126 Class B cast iron or ASTM A536 Grade 65-45-12 ductile iron and fully encapsulated with resilient facing per ASTM D2000-BG and ANSI/AWWA C517 requirements.

**5.4** Threaded valves shall have radial shaft bearings constructed of self-lubricating Type 316 stainless steel. The top thrust bearing shall be Teflon.

**5.5** 2 1/2 in. (60 mm) through 60 in. (1500 mm) plug valves shall have radial shaft bearings constructed of self-lubricating Type 316 stainless steel. The top thrust bearing shall be Teflon. The bottom thrust bearing shall be self-lubricating Type 316 stainless steel. Cover bolts shall be corrosion resistant with zinc plating.

Revised 9-24-12

**ECENTRIC PLUG VALVE SPECIFICATION**

DATE 6-7-06

 **VAL-MATIC®** VALVE AND MANUFACTURING CORP.

DRWG. NO.  
**VM-5800R-S**  
Sheet 1 of 2

**ECENTRIC PLUG VALVE**  
**Val-Matic® Specification**

**6 Actuators**

- 6.1 Threaded valves shall be equipped with a hand lever with a dial indicator and open memory stop.
- 6.2 Valves 2 ½ in. (60 mm) to 8 in. (200 mm) and 4 in. (100mm) to 6 in. (150 mm) 100% ported shall be equipped with a 2 inch square nut for direct quarter turn operation. The packing gland shall include a friction collar and an open position memory stop. The friction collar shall include a nylon sleeve to provide friction without exerting pressure on the valve packing.
- 6.3 When specified valves 4 in. (100 mm) and larger shall include a totally enclosed and sealed worm gear actuator with position indicator (above ground service only) and externally adjustable open and closed stops. The worm segment gear shall be ASTM A536 Grade 65-45-12 ductile iron with a precision bore and keyway for connection to the valve shaft. Bronze radial bearings shall be provided for the segment gear and worm shaft. Alloy steel roller thrust bearings shall be provided for the hardened worm.
- 6.4 All gear actuators shall be designed to withstand, without damage, a rim pull of 200 lb. on the hand wheel and an input torque or 300 ft-lbs. for nuts.
- 6.5 Buried service actuators shall be packed with grease and sealed for temporary submergence to 20 feet of water. Exposed worm shafts shall be stainless steel.

**7 Options**

- 7.1 When specified, the valve port area shall have not less than 100% of pipe area.
- 7.2 The interior and exterior of the valve shall be coated with an NSF/ANSI 61 approved fusion bonded epoxy.
- 7.3 The interior of the valve shall be coated with 8 mils SG-14 glass lining or 1/8" soft rubber lining.

**8 Manufacture**

- 8.1 Manufacturer shall demonstrate a minimum of ten (10) years' experience in the manufacture of plug valves. When requested, the manufacturer shall provide test certificates, dimensional drawings, parts list drawings and operation and maintenance manuals.
- 8.2 The exterior of the valve for above ground service shall be coated with a universal alkyd primer. Valve exterior for buried service shall be coated with an epoxy coating.
- 8.3 Valve shall be marked with the Serial Number, Manufacturer, Size, Cold Working Pressure (CWP) and the Direct and Reverse Actuator Pressure Ratings on a corrosion resistant nameplate.
- 8.4 Plug Valves shall be Series # 5600R (100% Port Flanged), 5700R (100% Port Mechanical Joint), 5800RTL (Threaded), 5800R (Flanged), 5800HP (Flanged), 5900R (Mechanical Joint) or 5900HP (Mechanical Joint) as manufactured by Val-Matic Valve and Mfg. Corporation, Elmhurst, IL. USA or approved equal.

Revised 9-24-12

**ECENTRIC PLUG VALVE SPECIFICATION**

DATE 6-7-06

 **VAL-MATIC®** VALVE AND MANUFACTURING CORP.

DRWG. NO.  
**VM-5800R-S**  
Sheet 2 of 2