



WORKING PRESSURE
 150 P.S.I. COLD WORKING PRESSURE-C.W.P.
 TEST PRESSURE
 1.5 TIMES COLD WORKING PRESSURE-C.W.P.

- | | | |
|--------------------|--------------------|--------------------------|
| 1. BODY | 9. BUSHING | 18. LOCK NUT |
| 2. COVER | 10. FLOAT ARM | 20. GUIDE SHAFT |
| 3. BAFFLE | 11. ORIFICE BUTTON | 28. PIPE PLUG |
| 4. SEAT | 12. PIVOT PIN | 33. CLEVIS |
| 5. FLOAT | 13. RETAINING RING | 34. LOCK WASHER |
| 6. GASKET | 14. PIPE PLUG | 35. GUIDE SHAFT RETAINER |
| 7. COVER BOLT | 16. PLUG | 36. PIPE PLUG |
| 8. RETAINING SCREW | 17. FLOAT RETAINER | |

SEE DRAWING NO. VM-801A-M FOR STANDARD MATERIALS OF CONSTRUCTION.
 SEE DRAWING NO. VM-801ASV-M FOR SUPER VALVE MATERIALS OF CONSTRUCTION.

Revised 2-3-10

WASTEWATER COMBINATION AIR VALVE

DATE 3-17-00

VAL-MATIC[®] VALVE AND MANUFACTURING CORP.

DRWG. NO.
VM-801A