

# AIR/VACUUM VALVE

4" - 20" SERIES NO. 100

## STANDARD MATERIALS OF CONSTRUCTION

<u>PART NO.</u>	<u>PART NAME</u>	<u>MATERIAL</u>
1	BODY	CAST IRON ASTM A126, CLASS B
2	COVER	CAST IRON ASTM A126, CLASS B
4	SEAT	BUNA-N
5	FLOAT	STAINLESS STEEL T304, ASTM A240
6	GASKET	COMPRESSED NON-ASBESTOS FIBER
7	COVER BOLT	ALLOY STEEL SAE, GRADE 5
8	RETAINING SCREW	STAINLESS STEEL T304, ASTM F593
9	GUIDE BUSHING	STAINLESS STEEL T303, ASTM A582
15	CUSHION	BUNA-N
23	HOOD	STEEL - #1020
24	HOOD RETAINING SCREW	STEEL (ZINC PLATED)
25	WASHER-EXTERNAL	STEEL (ZINC PLATED)
26	SEAT RETAINING SLEEVE	STAINLESS STEEL T304, ASTM A269
* 27	WASHER-INTERNAL	STAINLESS STEEL T304, ASTM A240
28	PIPE PLUG	STEEL

NOTE: ALL SPECIFICATIONS AS  
LAST REVISED.

\* NOT FURNISHED ON VALVE SIZES 4" & 6"

Revised 4-29-98

MATERIALS OF CONSTRUCTION

DATE 2/22/79

**VAL-MATIC**<sup>®</sup>

VALVE AND MANUFACTURING CORP.

DRWG. NO.

VM-104-M