



SEE DRWG. NO. VM-1A08-M FOR STANDARD MATERIALS OF CONSTRUCTION.

NOTES

1. THE DIRECTION OF OPENING MAY BE REVERSED BY PULLING KEY, CYCLING ACTUATOR 90°, AND THEN REINSERTING KEY AS SHOWN BY DOTTED LINES.
2. ACTUATOR MEETS AWWA C504, LATEST REVISION.

VALVE SIZE	150B MODEL NO.			250B MODEL NO.		
	HW	CHW	NUT	HW	CHW	NUT
4	1A08	1A08C	1A02	1A08	1A08C	1A02
6	1B08	1B08C	1B02	1B08	1B08C	1B02
8	1B08	1B08C	1B02	1B08	1B08C	1B02
10	1C12	1C12C	1C02	1C12	1C12C	1C02
12	1C16	1C16C	1C02	1C16	1C16C	1C02
14	1D24	1D24C	1D02	1D24	1D24C	1D02
16	1D24	1D24C	1D02	1D24	1D24C	1D02
18	1E24	1E24C	1E02	1E24	1E24C	1E02
20	1E24	1E24C	1E02	1E24	1E24C	1E02
24	1F24	1F24C	1F02	1F30	1F30C	1F02

Revised 11-19-01

ABOVE GROUND SERVICE TRAVELING NUT ACTUATOR FOR BUTTERFLY VALVE

DATE 10-19-99