

SURGEBUSTER™ SWING CHECK VALVE

STANDARD MATERIALS OF CONSTRUCTION

<u>PART NO.</u>	<u>PART NAME</u>	<u>MATERIAL</u>
1	BODY (2" - 24") BODY (30" - 42")	DUCTILE IRON ASTM A536, GRADE 65-45-12 CAST IRON ASTM A126, CLASS B
2	COVER (2" - 24") COVER (30" - 42")	DUCTILE IRON ASTM A536, GRADE 65-45-12 CAST IRON ASTM A126, CLASS B
3	DISC	BUNA-N W/ ALLOY STEEL & NYLON REINFORCEMENT
4	GASKET	COMPRESSED NON-ASBESTOS FIBER
5	COVER BOLT	ALLOY STEEL SAE GRADE 5, PLATED
6	BACKFLOW ACTUATOR (OPTIONAL)	BRASS
13	DISC ACCELERATOR	STAINLESS STEEL, TYPE 302
14	MECHANICAL INDICATOR (OPTIONAL, SIZES 3"-42")	STAINLESS STEEL, TYPE 316

NOTE: ALL SPECIFICATIONS AS
LAST REVISED.

Revised 1-3-07

MATERIALS OF CONSTRUCTION

DATE 5/21/03

VAL-MATIC®

VALVE AND MANUFACTURING CORP.

DRWG. NO.

VM-7202-M