

# Certificate of Compliance

Certificate Number **083107-EX6274**  
Report Reference **Ex6274 - August 28, 2003**  
Issue Date **2007 August 31**

Page 1 of 1



*Issued to:* **VAL-MATIC VALVE & MFG. CORP.**

905 Riverside Dr.  
Elmhurst, IL 60126

*This is to certify that  
representative samples of*

**Split Clapper Type Valves**

Models 8800W (wafer style) and 8800G (grooved style) check valves in the 2-1/2, 3, 4, 5, 6, 8, 10, and 12 in. sizes, for a rated pressure of 250 psig.

*Have been investigated by Underwriters Laboratories Inc.® in accordance  
with the Standard(s) indicated on this Certificate.*


*Standard(s) for Safety:*

The basic Standard used to investigate products in this category is UL 312 :  
"Check Valves for Fire Protection Service"

*Additional Information:*

Requirements for the installation and use of these valves are included in the Standards of the National Fire Protection Association for the installation of fire protection systems employing water, such as NFPA 11, 13, 14, 15, 20, 22, and 24. Underwriters Laboratories Inc. has not investigated this product for use in potable water systems. In the open position, the disc of a wafer or lug style check valve may extend beyond the end of the valve body. During installation, it should be determined that the check valve disc does not interfere with the operation of system components installed immediately adjacent to the check valve.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by:

Andrew Gurvey  
Underwriters Laboratories Inc.

Handwritten signature of Andrew Gurvey in blue ink.

Reviewed by:

Matthew Tennenbaum  
Underwriters Laboratories Inc.

Handwritten signature of Matthew Tennenbaum in blue ink.

UL CERTIFICATE FOR DUAL DISC CHECK VALVES

DATE 9-8-09

**VAL-MATIC®** VALVE AND MANUFACTURING CORP.

DRWG. NO.

**SS-2479**