



COLD WORKING PRESSURE (CWP)
300 P.S.I.
TEST PRESSURE = 1.5 TIMES
COLD WORKING PRESSURE

SEE DRAWING NO. VM-100VB -M FOR STANDARD MATERIALS OF CONSTRUCTION.

| VALVE SIZE | MODEL NO. * | A | B | INLET SIZE | OUTLET SIZE |
|------------|-------------|------|-------|-------------|-------------|
| 1/2" | 100VB | 6.13 | 7.00 | 1/2" N.P.T. | 1/2" N.P.T. |
| 1" | 101VB | 7.00 | 9.50 | 1" N.P.T. | 1" N.P.T. |
| 2" | 102VB | 9.50 | 12.00 | 2" N.P.T. | 2" N.P.T. |
| 3" | 103VB | 9.50 | 12.50 | 3" N.P.T. | 3" N.P.T. |

- 1 BODY
- 2 COVER
- 3 BAFFLE
- 4 SEAT
- 5 FLOAT
- 6 GASKET
- 7 COVER BOLT
- 8 RETAINING SCREW
- 9 GUIDE BUSHING
- 14 PIPE PLUG
- 20 GUIDE SHAFT
- 21 SPRING

Revised 11-18-11

VACUUM BREAKER AIR VALVES

DATE 9-18-84



DRWG. NO.
VM-100VB