

1"-16" FLOODSAFE FIELD TEST KIT

SERIES NO. SPK-1300

STANDARD MATERIALS OF CONSTRUCTION

<u>PART NO.</u>	<u>PART NAME</u>	<u>MATERIAL</u>
1	TEST COCK A-C (1"-4") TEST COCK A-C (6"-16")	BRASS BODY WITH SST304 BALL BRONZE BODY & BALL
2	TEST PLATE	ALUMINUM, TYPE T6061
3	TEST BAR	ALUMINUM, TYPE T6061
4	O-RING	BUNA-N, ASTM D2000
5	WING THUMB SCREW	ZINC-PLATED MALLEABLE IRON
6	PIPE NIPPLE	SCHEDULE 40 BRONZE
7	PIPE ELBOW	CLASS 150# BRONZE
8	REDUCER	CLASS 150# BRASS
9	FEMALE QUICK DISCONNECT	BRASS
10	MALE QUICK DISCONNECT	BRASS
11	WATER LEVEL ASSEMBLY	PVC, ASTM D1784

NOTE: ALL SPECIFICATIONS AS
LAST REVISED.

FLOODSAFE® FIELD TEST KIT

DATE 9-29-20

DRWG. NO.

VM-1301FT-M

VAL-MATIC®

VALVE AND MANUFACTURING CORP.