

BURIED SERVICE WORM GEAR ACTUATOR FOR BUTTERFLY VALVE

4A02 through 4E02

<u>PART NO.</u>	<u>PART NAME</u>	<u>MATERIAL</u>
1	HOUSING	CAST IRON ASTM A126, CLASS B
2	WORM GEAR	BRONZE
3	WORM	HARDENED STEEL
4	COVER	CAST IRON ASTM A126, CLASS B
6	O-RING	BUNA-N 70 DUROMETER
7	ROLLER THRUST BEARING	CARBON STEEL, GRADE 1045
8	BEARING	PERMANENTLY LUBRICATED BRONZE
9	SHAFT	CARBON STEEL A108, GRADE 1040
10	GASKET	COMPRESSED NON-ASBESTOS FIBER
12	OPERATING NUT	CAST IRON ASTM A126, CLASS B
14	COVER BOLT	CARBON STEEL
18	WORM SPRING PIN	CARBON STEEL
19	SPRING PIN	CARBON STEEL
20	STOP ADJUSTMENT SCREW	CARBON STEEL
21	JAM NUT	STEEL
23	O-RING	BUNA-N

NOTE: ALL SPECIFICATIONS AS
LAST REVISED.

Revised 8-10-01

MATERIALS OF CONSTRUCTION

DATE 10/12/00

VAL-MATIC[®] VALVE AND MANUFACTURING CORP.

DRWG. NO.

VM-4A02-M