



NOTES

1. THE DIRECTION OF OPENING MAY BE REVERSED BY PULLING KEY WITH THE VALVE IN THE CLOSED POSITION, CYCLING ACTUATOR 90°, AND THEN REINSERTING KEY AS SHOWN BY DOTTED LINES.
2. ACTUATOR MEETS AWWA C504, AND AWWA C507 LATEST REVISION.
3. SEE DRAWING NO. VM-LS1A-M FOR STANDARD MATERIALS OF CONSTRUCTION.
4. FOR BURIED OR SUBMERGED SERVICE, UNIT PACKED WITH GREASE, NO INDICATION.

DIMENSION, INCHES							
ACTUATOR SIZE	A	B	C	D	E	F	G
LS-1A	6.89	2.52	0.63	1.00	4.00	0.25	2.00
LS-2A	7.71	2.52	0.63	1.00	4.00	0.25	2.00
LS-3A	11.06	3.25	0.63	1.25	4.00	0.25	2.75
LS-4A	12.81	3.25	0.63	1.25	4.00	0.25	2.75

Revised 4-19-11

TRAVELING NUT ACTUATOR

DATE 8-22-08