



WORKING PRESSURE  
150 PSI COLD WORKING PRESSURE

TEST PRESSURE  
1.5 TIMES COLD WORKING PRESSURE

- |    |             |    |                 |
|----|-------------|----|-----------------|
| 1  | BODY        | 7  | COVER BOLT      |
| 2  | COVER       | 8  | RETAINING SCREW |
| 3  | BAFFLE      | 9  | GUIDE BUSHING   |
| 4  | SEAT        | 14 | PIPE PLUG       |
| 5  | FLOAT       | 20 | GUIDE SHAFT     |
| 5L | LOWER FLOAT | 28 | PIPE PLUG       |
| 6  | GASKET      | 36 | PIPE PLUG       |

SEE DRAWING NO. VM-301AS-M FOR STANDARD MATERIALS OF CONSTRUCTION.

STAINLESS STEEL WASTEWATER AIR/VACUUM VALVE

DATE 5-2-14

**VAL'MATIC**

VALVE AND MANUFACTURING CORP.

DRWG. NO.

VMC-301AS